

(315) 437-2533 (315) 437-1775 www.rustonpaving.com

June 6, 2012

Metalico Aluminum Recovery, Inc. C/O: Joe Camello 6223 Thompson Road Syracuse, New York 13206

Dear Mr. Camello:

Re: CAMU Cover Repairs

I have completed the inspection of the asphalt cover on the CAMU area. I have found a few areas where the existing asphalt patches need to be cracked sealed and a few spots of vegetation growing along the joint between the concrete dolly apron and asphalt pavement. Vegetation along the slopes of the pavement have been removed and are not entering the CAMU cap area.

Repair Procedures:

Crack seal edges and existing asphalt patches. Remove vegetation

All repairs were completed by June 6, 2012.

Should you have any questions or concerns, please contact me at (315) 437-2533.

Sincerely,

Ruston Paving Co., Inc.

bristol & Lewin

Chris Laurin

Project Manager